
	<p style="text-align: center;">नवी मुंबई महानगरपालिका</p>	<p style="text-align: center;">Navi Mumbai</p>  <p style="text-align: center;">मुलगी वाचवा, देश वाचवा</p> <p style="text-align: center;">Municipal Corporation</p>
	<p>आरोग्य विभाग, तिसरा मजला, नमुंमपा मुख्यालय, से. 15ए सि. बी. डी. नवी मुंबई 400 614 दूरध्वनी क्र : 27567261</p>	<p>Health Dept. 3rd floor. N.N.M.C. Head Office, Sec. 15A CBD NAVI MUMBAI - 400 614 Tel No. 27567261</p>

No.NMMC/Health/ 2241 /2024

Date :- 26 / 03 / 2024


To,
The Principal,
Terna Orchid International School
Plot 23, Sector 1, Koperkhairne
Navi Mumbai

Sub:-About Safe Drinking Water Certificate

Ref- 1.Your application no. 4277, dated 20.2.2024.
2.Report Of water sample dated 4.03.2024.

As Per your application regarding safe drinking water facilities and hygienic sanitary conditions Terna Orchids the International School, Plot no 23, Sector 1, Koperkhairne, Navi Mumbai water sample report submitted by you on 18.03.2024, it is understood that drinking water facilities are as per norms.

This certificate is issued for period of one year from the date of this certificate provided norms prescribed by the State Govt are maintained.




Dr. Prashant Jawade
Medical Officer of Health
Navi Mumbai Municipal Corporation



Principal

Terna Orchids The International School
Plot No. 23, Sector-1, Koperkhairane
Navi Mumbai-400 709
Affiliation No.1130678



Manager

Terna Orchids The International School
Plot No. 23, Sector-1, Koperkhairane
Navi Mumbai-400 709



नवी मुंबई
महानगरपालिका

Navi Mumbai
Municipal Corporation

पर्यावरण प्रयोगशाळा
अग्रोळी पुलाखाली, सी.बी.डी. बेलापूर, नवी मुंबई 400 614.
दुरध्वनी क्र. : 2757 9882



NMMC/Environment Laboratory/133/2023-2024

Date : 29/02/2024

Date of sample received. : 29/02/2024 Date of sample testing : 29/02/2024 to 04/03/2024

Customer's Name and Location : Terna Orchid International School,
Plot No.23, Sec- 1,
Koparkhairne, Navi Mumbai - 400708

TEST REPORT

Sr. No.	Testing Parameter	Test Result	Test Standards (IS 10500 : 2012)
01	pH	7.1	6.5 - 8.5
02	Turbidity	0.0	Max. 5.0 N.T.U.
03	Residual Chlorine	0.1	Min. 0.2 mg/l
04	Bacteriological Test		
	Total Coliforms	0	0 per 100 ml
	E. Coli	- ve	- ve
	F. Coli	- ve	- ve

Test Report No. : 133

Date : 04/03/2024

Conclusion : Test results of the sample are based on the sample submitted in the laboratory.

Lab Chemist

Lab Incharge

Environment Laboratory

Navi Mumbai Municipal Corporation